

April 20, 2016

CITY OF WICHITA, KANSAS

REQUEST FOR FORMAL BID NUMBER FB640080

ADDENDUM # 2

PUBLIC WORKS & UTILITIES DEPARTMENT/FLEET & FACILITIES DIVISION

DESCRIPTION: Park Forestry Building Remodel

OPENING DATE: FRIDAY, APRIL 22, 2016, AT 10:00 A.M.

The following additions, deletions, and/or changes have been added to the specifications and made a part of this formal bid FB640080.

- 1. Addendum #2 Items Attached.
- 2. Revised Bid Form Attached changing description of Alternate No. 1 and Alternate No. 2.

FOR BIDS SUBMITTED ONLINE ELECTRONICALLY (<https://ep.wichita.gov>): YOU NEED TO REVIEW, MAKE ANY NECESSARY CHANGES AND RESUBMIT YOUR BID. THE ADDENDUM WILL BE ACKNOWLEDGED WHEN YOU HAVE READ THE LEGAL BID ADDENDUM FORM.

ALL BIDS RECEIVED ON WEDNESDAY, APRIL 20, 2016, BEFORE NOON WILL BE RETURNED WITH THIS ADDENDUM. IF YOUR BID IS NOT RETURNED AND YOU WANT IT BACK, PLEASE CALL THIS OFFICE (316) 268-4636.

Melinda A. Walker
Purchasing Manager

The undersigned acknowledges receipt of this Addendum and the bid submitted herewith is in accordance with the information, instruction and stipulations set forth herein.

Date

Company Name

Signature of Company Representative

Print Name of Company Representative

Title

ADDENDUM NO. 2: CHANGE NARRATIVE

Issue Date: April 19, 2016

Project: Park and Recreation/Forestry Building Remodel
City of Wichita
1205 S. McLean Boulevard
Wichita, KS 67213

Project No: LK Architecture Project 14100.20

Owner: City of Wichita, Kansas
455 North Main
Wichita, Kansas 67202

Architect: LK Architecture
345 Riverview, Suite 200
Wichita, Kansas 67203

General Clarifications:

1. This Addendum shall be considered revisions to and a part of the Contract Documents.
2. Security and Data materials and installations of security and data to the building and site shall be provided by the City and not in this project's contract unless noted otherwise. But, this project's contractor shall coordinate closely with the City's separate contractors as to not impact this project's schedule, costs, safety or maintaining weather and water tightness of the building.

Drawings:

1. Sheet SA2:
The new concrete paving at the northwest corner extends from the north property line to the sliding gate (indicated by the "cross hatching"). The note shall be revised to read "Alternate #1" New 6", 4500 psi concrete slab with 6"x 12" W4 x W4 welded wire fabric over Geo-Tech fabric on 6" AB3."
2. Sheets A3 & A4:
Foam insulation occurs at the interior side (underside) of the roof decks at all locations except Room #100 (Equipment Storage). Delete the foam roof insulation at Room #100.
3. Sheet A4, Details 5,6 &7:
Delete "insulation to remain" at roof and add foam and thermal barrier to the underside of the deck as is typical elsewhere. Conditions are similar to wall sections P1 & P1a on sheet A1 except that the roof is flat. The existing roof deck is to remain.

Specifications:

1. Section 01 23 00, 3.1, A. Alternate #1:
Revise to read: Provide concrete paving at the northwest corner extending from the north property line to the sliding gate (indicated by the "cross hatching" on drawing sheet SA2).new 6", 4500 psi concrete slab with 6"x 12" W4 x W4 welded wire fabric over Geo-Tech fabric on 6" AB3."

2. Section 01 23 00, 3.1, A. Alternate #2:
Clean, Prep and Paint the trusses, cross bridging, and the roof purlins.

End of Addendum No. 2

FORMAL BID

FB640080

Public Works Fleet & Facilities

Park Forestry Building Remodel

Responses are due before:

Friday, April 22, 2016 10:00:00AM

RETURN TO:

City of Wichita
Purchasing Manager
City Hall, 12th Floor
455 N Main
Wichita KS 67202



CONTACT INFORMATION:

Contact: Clarence Rose

Phone: (316) 268-4414

Fax: (316) 268-4656

455 North Main
12TH FLOOR
Wichita, KS 67202

e-mail: crose@wichita.gov

DELIVERY INFORMATION

Deliver To: Jay Newton
Fleet & Facilities Superintendent
1801 S McLean Blvd
Suite C
Wichita, KS 67213-

Phone: (316) 268-4074

Fax:

e-mail:

PLEASE QUOTE DELIVERED PRICES ON THE EQUIPMENT, MATERIAL OR SERVICES LISTED BELOW

GROUP 1

<u>Item</u>	<u>Description</u>	<u>Qty</u>	<u>U.O.M.</u>	<u>Unit Price</u>	<u>Extended Amount</u>
1	Base Bid: Labor, Material, and Equipment for Forestry Building Remodel, 1205 South McLean Blvd. as per Specifications and Drawings.	1.00	LS	_____	_____
2	Alternate No. 1: Provide concrete paving at the northwest corner extending from the north property line to the sliding gate (indicated by the "cross hatching" on drawing sheet SA2) new 6", 4500 psi concrete slab with 6"x12" W4 x W4 welded wire fabric over Geo-Tech fabric on 6" AB3. Lump Sum Amount to ADD to the Base Bid.	1.00	LS	_____	_____
3	Alternate No. 2: Clean, prep and paint trusses, cross bridging, and the roof purlins. Lump Sum Amount to ADD to the Base Bid.	1.00	LS	_____	_____
4	Alternate No. 3: Deleted windows at Office Nos. 106, 107, 108 and 109. Lump Sum Amount to DEDUCT from the Base Bid.	1.00	LS	_____	_____

GROUP 1 TOTAL

Solicitation Total:

\$

Vendor Name

Telephone Number (including area code)

Vendor Address

Fax Number (including area code)

Vendor City/State/ZIP

E-mail Address

Signature

Vendor TIN/FEIN/SSN

Printed Name

Billing Terms

Title

Delivery or Completion Date

IN SUBMITTING THE ABOVE, THE VENDOR EXPRESSLY AGREES THAT, UPON ACCEPTANCE OF ANY OR ALL ITEMS, UNDER THE TERMS AND CONDITIONS SHOWN ABOVE AND ATTACHED TO THIS FORM, BY THE CITY OF WICHITA, A CONTRACT SHALL THEREBY BE CREATED.

THIS FORMAL BID FORM MUST BE SIGNED!