

April 28, 2016

CITY OF WICHITA, KANSAS

REQUEST FOR FORMAL BID NUMBER FB640088

ADDENDUM # 1

PUBLIC WORKS & UTILITIES DEPARTMENT/FLEET & FACILITIES DIVISION

DESCRIPTION: Re-Roof Museum of World Treasures

OPENING DATE: FRIDAY, MAY 6, 2016, AT 10:00 A.M.

The following additions, deletions, and/or changes have been added to the specifications and made a part of this formal bid FB640088.

1. Addendum #1 Items Attached.

FOR BIDS SUBMITTED ONLINE ELECTRONICALLY (<https://ep.wichita.gov>): YOU NEED TO REVIEW, MAKE ANY NECESSARY CHANGES AND RESUBMIT YOUR BID. THE ADDENDUM WILL BE ACKNOWLEDGED WHEN YOU HAVE READ THE LEGAL BID ADDENDUM FORM.

ALL BIDS RECEIVED ON THURSDAY, APRIL 28, 2016, BEFORE NOON WILL BE RETURNED WITH THIS ADDENDUM. IF YOUR BID IS NOT RETURNED AND YOU WANT IT BACK, PLEASE CALL THIS OFFICE (316) 268-4636.

Melinda A. Walker
Purchasing Manager

The undersigned acknowledges receipt of this Addendum and the bid submitted herewith is in accordance with the information, instruction and stipulations set forth herein.

Date

Company Name

Signature of Company Representative

Print Name of Company Representative

Title



The following revisions and additions to the Specifications and Drawings are hereby made a part of the Contract Documents.

1-1 DRAWING SHEET A1.1 ROOF PLAN

Change note at right side of Floor Plan to read:

“Contractor to remove and dispose of existing Christmas lights which are siliconed to the existing coping. If the City decides at a later date to install new Christmas lights, this will be handled as a separate project. If lights are provided by the City, they will be installed in a manner that will not affect the roofing warranty.”

1-2 DRAWING SHEET A1.1 AND DETAIL 10/A1.2

At existing elevator penthouse, the bottom of wall flashing installation will likely not be able to be achieved without removing the existing metal siding. Include in Scope of Work removal of all existing metal siding and trim. Extend roof flash 24” minimum up Penthouse wall and install new corrugated galvanized metal siding and metal corner trim similar to existing. Provide Tyvek moisture barrier under siding and rubber closure strips at vertical corners. Install using screw fasteners with neoprene washer. Approximate size of Penthouse is 11’ x 12’ x 8’ high.

1-3 SPEC SECTION 01 30 00-1.8A

Add the following:

“Access to roof during construction shall be from the exterior of building on the west side. Coordinate exact location with Owner prior to start of construction.”

END OF ADDENDUM #1