

May 11, 2016

CITY OF WICHITA, KANSAS

REQUEST FOR FORMAL BID NUMBER FB640089

ADDENDUM # 2

PUBLIC WORKS & UTILITIES DEPARTMENT/FLEET & FACILITIES DIVISION

DESCRIPTION: Shops 5 & 6 Repair and Paving at Central Maintenance Facility

OPENING DATE: FRIDAY, MAY 13, 2016, AT 10:00 A.M.

The following additions, deletions, and/or changes have been added to the specifications and made a part of this formal bid FB640089.

- 1. Addendum #2 Items Attached.
- 2. Revised Bid Form attached with revision to the description on Unit Price #3.

FOR BIDS SUBMITTED ONLINE ELECTRONICALLY (<https://ep.wichita.gov>): YOU NEED TO REVIEW, MAKE ANY NECESSARY CHANGES AND RESUBMIT YOUR BID. THE ADDENDUM WILL BE ACKNOWLEDGED WHEN YOU HAVE READ THE LEGAL BID ADDENDUM FORM.

ALL BIDS RECEIVED ON WEDNESDAY, MAY 11, 2016, BEFORE NOON WILL BE RETURNED WITH THIS ADDENDUM. IF YOUR BID IS NOT RETURNED AND YOU WANT IT BACK, PLEASE CALL THIS OFFICE (316) 268-4636.

Melinda A. Walker
Purchasing Manager

The undersigned acknowledges receipt of this Addendum and the bid submitted herewith is in accordance with the information, instruction and stipulations set forth herein.

Date

Company Name

Signature of Company Representative

Print Name of Company Representative

Title

FORMAL BID

FB640089

Public Works Fleet & Facilities

Shops 5 & 6 Repair & Paving

Responses are due before:

Friday, May 13, 2016 10:00:00AM

RETURN TO:

City of Wichita
Purchasing Manager
City Hall, 12th Floor
455 N Main
Wichita KS 67202



CONTACT INFORMATION:

Contact: Clarence Rose

Phone: (316) 268-4414

Fax: (316) 268-4656

455 North Main
12TH FLOOR
Wichita, KS 67202

e-mail: crose@wichita.gov

DELIVERY INFORMATION

Deliver To: Jay Newton
Fleet & Facilities Superintendent
1801 S McLean Blvd
Suite C
Wichita, KS 67213-

Phone: (316) 268-4074

Fax:

e-mail:

PLEASE QUOTE DELIVERED PRICES ON THE EQUIPMENT, MATERIAL OR SERVICES LISTED BELOW

GROUP 1

<u>Item</u>	<u>Description</u>	<u>Qty</u>	<u>U.O.M.</u>	<u>Unit Price</u>	<u>Extended Amount</u>
1	Base Bid: Labor, Material, and Equipment for Shops 5 & 6 Repair and Paving at the Central Maintenance Facility, 1801 S. McLean Blvd. as per Drawings and Specifications.	1.00	LS	_____	_____
2	Option 1- Unit Price No. 1: The cost to remove existing paving and base outside of the Base Bid area and replace it with a paving section (including stripping) per detail 1/C3.0 (8" CONCRETE PAVEMENT section and without the Tensor Geogrid) per the drawings and specifications. Extent of the area to be replaced will be determined by the owner. Cost per Square Foot.	1.00	SF	_____	_____
3	Option 2- Unit Price No. 2: The cost to remove and replace, per Wall Section 2/A1.0, any EIFS and gypsum sheathing which is outside the limits of the Base Bid shown on 1/A1.0. Cost per Square Foot.	1.00	SF	_____	_____
4	Option 3- Unit Price No. 3: The cost to add the Tensor Geogrid to detail 1/C3.0 (8" CONCRETE PAVEMENT section). Cost per Square Foot.	1.00	SF	_____	_____

GROUP 1 TOTAL

Solicitation Total:

\$

Vendor Name

Telephone Number (including area code)

Vendor Address

Fax Number (including area code)

Vendor City/State/ZIP

E-mail Address

Signature

Vendor TIN/FEIN/SSN

Printed Name

Billing Terms

Title

Delivery or Completion Date

IN SUBMITTING THE ABOVE, THE VENDOR EXPRESSLY AGREES THAT, UPON ACCEPTANCE OF ANY OR ALL ITEMS, UNDER THE TERMS AND CONDITIONS SHOWN ABOVE AND ATTACHED TO THIS FORM, BY THE CITY OF WICHITA, A CONTRACT SHALL THEREBY BE CREATED.

THIS FORMAL BID FORM MUST BE SIGNED!

ADDENDUM NO.2: CHANGE NARRATIVE

Issue Date: May 11, 2016

Project: Central Maintenance Facility
Shops 5 & 6 Restoration
City of Wichita
1801 McLean Boulevard
Wichita, KS 67213

Project No: LK Architecture Project 14100.24

Owner: City of Wichita, Kansas
455 North Main
Wichita, Kansas 67202Architect: LK Architecture
345 Riverview, Suite 200
Wichita, Kansas 67203**General Clarifications:**

1. This Addendum shall be considered revisions to and a part of the Contract Documents.

Drawings:

1. Drawing sheet C1.0: Delete notes to "remove existing bollards and guardrails". Existing bollards and guardrails are to remain (see Addendum #1, Drawings: item #5.,f.).
2. Drawing sheet C2.0 & C3.0: Provide 6" rock base in lieu of 5" noted on C2.0, Note 10.
3. Drawing sheet C4.0: Delete the silt fencing except for areas where it is required by the City of Wichita standards and regulations and along McLean Boulevard. If not required, the contractor shall be responsible for cleaning and maintaining adjacent paved or grass areas.
4. Drawing sheet M2.01: Provide concrete pads and new bollards as shown
5. Drawing sheet E1.0:
 - a. The Distribution Panel DP-P is an existing panel and not new. (See Plan A/E1.0)
 - b. Connect RTU PS1 and PS2 to panel DP-P. 277/480V wiring already exists to Panel DP-P. The contractor is responsible for conduit and wire to the RTU's.

Specifications:

1. Section 03 30 00, 2.1 "STEEL REINFORCMENT"
Add 2.1 B.: Concrete Pavement Reinforcement: 6x6 W4 xW4 per detail 1/ C3.0.

Addendum #1 Clarifications:

1. Section 01 23 00, 3.1 "SCHEDULE OF UNIT PRICES", subparagraph c:
Provide cost for Tensor Geogrid per detail 1/C3.0 not Geotectile Fabric.

End of Addendum No. 2