



WICHITA, KANSAS

**ADDENDUM NO. 1  
TO THE PROPOSAL FB640091**

Water Distribution System in 127th Street north of Pawnee  
(north of Pawnee, west of 127th Street East)  
448-90640 754075

**TO BE BID: May 6, 2016**

The following changes and additions shall be made to the plans and proposal.

1. **Revised Title Sheet.** Engineering's project number has been corrected on the attached revised plan title sheet.
2. **Fitting Size.** The fittings for this project shall all be 16". Some callout sizes are incorrect on the plan sheets.
3. **Restrained Joint Pipe.** RJ pipe is called out within 60' of the cross fitting. A bid item for Pipe, WL 16" RJ has been added to the bid proposal, and 120' of pipe has been subtracted from the standard pipe bid item.
4. **Sod.** Disturbed areas adjacent to developed property shall be restored with sod to match existing conditions. Cost is subsidiary to Site Restoration.
5. **Anchored Valves.** The two anchored valves specified for construction with this project are standard anchored valves, and not anchored valves, special. The bid proposal has been corrected to remove the word "special".
6. **Tie in valves.** The existing tie-in valves at each end of the project are anchored.

**\*\*For vendors not submitting bids online, the revised Solicitation form can be obtained from QuikPrint at 316-942-2208.\*\***

\* \* \* \* \*

Each bidder is required to acknowledge receipt of this Addendum by his signature affixed hereto and to file same with and attached to his bid. Any Bid Proposal that is returned without all addenda signed and included in the Proposal shall be considered an invalid Proposal.

May 4, 2016

Gary Janzen, P.E.  
City Engineer

Date \_\_\_\_\_

**Signature of Bidder**

**BIDDER:** \_\_\_\_\_  
*(print or type name of firm)*

**ADDRESS:** \_\_\_\_\_

**AUTHORIZED AGENT:** \_\_\_\_\_  
*(Signature)*

\_\_\_\_\_  
*(print or type name of authorized agent)*