



WICHITA, KANSAS

**ADDENDUM NO. 4**  
TO THE PROPOSAL FB640092

Re-use Water Pump Station  
(east of Hydraulic, north of 63rd Street South)

468-85112 665009

**TO BE BID: May 20, 2016**

The following changes and additions shall be made to the plans and proposal.

1. ***Builder's Risk Insurance.*** The Contractor shall purchase and maintain, throughout the duration of the Project and through the date the final payment has been made or until no person or entity has an insurable interest in the Project, including the interest of the Owner, Contractor, subcontractors, sub-subcontractors, Builder's Risk insurance in the amount described below, written on an "all risk"/replacement cost basis, to include coverage for, but not limited to:
  - (1) ensuing loss from faulty workmanship, non-conforming work materials, omission or deficiency in design or specifications (\$500,000),
  - (2) damage or loss caused by the perils of fire, earth movement, earthquake, flood, theft, vandalism and malicious mischief debris removal and testing (\$500,000).
  - (3) Contractor shall be responsible for paying any and all deductibles.
2. ***Elevation Correction.*** On sheet M5.0, the top of the wall of the Existing Aeration Basin is incorrectly shown as 1285.50. The correct elevation is 1265.50.
3. ***Crushed Concrete Base in Lieu of Crushed Rock Base.*** Plan sheet C3.1, Detail 1 and Addendum 2 refer to the geotechnical report prepared by Allied Laboratories. In that report the pavement section calls for 8" of AB-1, AB-2, AB-3, or chemically stabilized soil reinforced with separation geotextile. Crushed Concrete Base and geogrid per City Standard Specifications is acceptable for base material. In addition, Plan sheet C3.1, Detail 10 shows 6" of Crushed Rock Base reinforced with geogrid covered with 2" of ¾" Crushed Rock Surface. 6" of Crushed Concrete Base with geogrid is acceptable in lieu of the 6" Crushed Rock Base with geogrid.
4. ***Sump Pump.*** No sump pump is required in the sump pit.
5. ***Floor Drain in Chlorination Room.*** No floor drain is required in the Chlorination Room.

\*\*\*\*\*

Each bidder is required to acknowledge receipt of this Addendum by his signature affixed hereto and to file same with and attached to his bid. Any Bid Proposal that is returned without all addenda signed and included in the Proposal shall be considered an invalid Proposal.

May 18, 2016

Gary Janzen, P.E.  
City Engineer

Date \_\_\_\_\_

**Signature of Bidder**

**BIDDER:** \_\_\_\_\_  
*(print or type name of firm)*

**ADDRESS:** \_\_\_\_\_

**AUTHORIZED AGENT:** \_\_\_\_\_  
*(Signature)*

\_\_\_\_\_  
*(print or type name of authorized agent)*