

June 10, 2016

CITY OF WICHITA, KANSAS

REQUEST FOR FORMAL BID NUMBER FB640124

ADDENDUM # 1

PUBLIC WORKS & UTILITIES DEPARTMENT/ STORM WATER DIVISION

DESCRIPTION: Generator Maintenance

OPENING DATE: FRIDAY, JUNE 17, 2016, AT 10:00 A.M.

The following additions, deletions, and/or changes have been added to the specifications and made a part of this formal bid FB640124.

**Questions and Answers:**

Q: What is the duration of the load bank that you require during maintenance, 2 or 4 hour?


A: A 2 hour load bank is sufficient,

Q: Is this contract only for 1 service per year, Semi-Annual, or Quarterly Services?

A: It is for only One (1) service per year.

ALL BIDS RECEIVED ON **FRIDAY, JUNE 10, 2016, BEFORE NOON** WILL BE RETURNED WITH THIS ADDENDUM. IF YOUR BID IS NOT RETURNED AND YOU WANT IT BACK, PLEASE CALL THIS OFFICE (316) 268-4636.

Each vendor is required to acknowledge receipt of this Addendum by their signature affixed hereto and to file same with and attached to this bid.

  
Melinda A. Walker  
Purchasing Manager

\*\*\*\*\*

The undersigned acknowledges receipt of this Addendum and the bid submitted herewith is in accordance with the information, instruction and stipulations set forth herein.

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Signature of Company Representative

\_\_\_\_\_  
Print Name of Company Representative

\_\_\_\_\_  
Title