



WICHITA, KANSAS

ADDENDUM NO. 2
TO THE PROPOSAL FB640126

Re-use Water Supply System to serve Spirit AeroSystems
(east of Hydraulic, north of 63rd Street South)

468-85095 620784

TO BE BID: June 17, 2016

The following changes and additions shall be made to the plans and proposal.

1. **Line Marking Tape.** Line marking tape shall be colored purple with the wording “CAUTION BURIED RECLAIMED WATER LINE BELOW” or similar wording referencing recycled, non-potable water.
2. **Plan Sheet 7 of 36.** Levee Crossing Note 2 - AWWA C153 Compact DICL Fittings that are COW Standard are allowed.
3. **Bid Item Clarification.** The intent of the bid item “Concrete Sidewalk Removed & Replaced” is to compensate the Contractor for portion(s) of the sidewalk bike trail (generally located east of K-15 and south of Turnpike Drive) that must be removed and replaced to accommodate re-use water pipeline construction. The extent of the removal of this sidewalk bike trail must be approved by the City’s representative prior to its removal.
4. **Geotechnical Borings.** Two geotechnical borings are attached for information only.
5. **Fusible PVC Pipe.** Addendum #1, Item 9 references “12” fusible PVC is acceptable on this project”. Specifications for Fusible PVC Pipe are attached.

Each bidder is required to acknowledge receipt of this Addendum by his signature affixed hereto and to file same with and attached to his bid. Any Bid Proposal that is returned without all addenda signed and included in the Proposal shall be considered an invalid Proposal.

June 15, 2016

Gary Janzen, P.E.
City Engineer

Date _____

Signature of Bidder

BIDDER: _____
(print or type name of firm)

ADDRESS: _____

AUTHORIZED AGENT: _____
Signature)

(print or type name of authorized agent)